



K.Dis.No.6473/C1/2025
Dated.22.05.2025

O/o.the Director of Fire & Rescue Service,
No.17, Rukmani Lakshmipathi Salai,
Egmore, Chennai – 600 008.

Licence No.370/2025 (Renewal)

Ref: (1) Online Application from the **M/s. Padanilam Welfare Trust, Kanyakumari, Online Token No.271096**, Dated:20.03.2025.

(2) Letter R.C.No.938/B/2025, dated:09.05.2025 from the Chairman, MSB Inspection Committee, **Tirunelveli Region, Tirunelveli.**

With reference to the letter first cited above the Fire Licence is **renewed** as under, based on the recommendations conveyed in the reference 2nd cited above.

FIRE & RESCUE SERVICES LICENCE

The Fire Licence is hereby **renewed** under section 13 of the Tamil Nadu Fire and Rescue Service Act 1985 for the multi-storied building classified as **Group A Residential Building, Sub-Division A-3 Dormitories (Hostel), Group B Educational Building, Sub-Division B-2 College, Group C Institutional Building, Sub-Division C-1 Hospitals and Group D Assembly Building, Sub-Division D-2 Auditorium of M/s. Padanilam Welfare Trust, Velayudhan Pillai Memorial Hospital Complex**, consists of building details follows as,

Sl. No.	Building description	Floor details	Height of the building (in meters)	Total built-up area (in sq. mtrs)
1	Medical college cum hospital (530 bed facility)	8 floors (G + 7)	29.90	33643.21

2	Medical college	6 floors (G + 5)	24.60	20597.72
3	B.Sc., nursing college	5 floors (G + 4)	18.10	5125.67
4	Dental college	6 floors (G + 5)	21.70	8771.60
5	Diploma nursing	4 floors (G + 3)	14.50	4431.78
6	Old dental college	5 floors (G + 4)	18.10	2379.35
7	Nursing college hostel (1)	5 floors (G + 4)	18.50	3148.25
8	Nursing college hostel (2)	5 floors (G + 4)	18.10	1603.79
9	Nursing college hostel (3)	6 floors (G + 5)	20.00	1807.77
10	MBBS boys hostel	5 floors (G + 4)	18.05	9498.08
11	MBBS ladies hostel	5 floors (G + 4)	21.05	9993.08
12	BDS hostel	4 floors (G + 3)	18.10	8758.73
13	Staff quarters (1)	4 floors (G + 3)	14.30	1769.39
14	Staff quarters (2)	4 floors (G + 3)	14.30	1762.39
15	Staff quarters (3)	4 floors (G + 3)	14.20	1768.92
16	Workers quarters	4 floors (G + 3)	18.10	2628.78
17	Auditorium	Ground floor	09.10	2527.61

at **Kulasekaram, Kanniyakumari District** subject to the following conditions and such other conditions as may be prescribed from time to time. This licence is valid for **THREE YEARS** from **22.05.2025** to **21.05.2028** and should be renewed on **22.05.2028**.

CONDITIONS

1. The available fire fighting equipments should be maintained in good and working condition at all times.
2. The hospital authorities shall arrange for fire fighting training to all of their employees.
3. Periodical maintenance should always be ensured to keep all fire protection equipment and systems in good working condition.
4. "Mock drill" should be periodically conducted. The date of conduct should be informed to the District Officer, Nagercoil District well in advance to enable the team to make suggestions, if any.
5. Trained fire personnel should be available to operate the systems in case of any emergency.
6. All fire fighting equipment should always be kept in good working condition at all times.

7. Any erection of a permanent or temporary structure should be intimated to this Fire and Rescue Services Department.
8. With reference to air-conditioning it should not exceed the electricity board load on any account.
9. Available set back area on all sides should be maintained to withstand the weight of 45 tons of fire fighting vehicle.
10. House keeping / dumping of waste material any where should be avoided. Dust bins should be cleared everyday.
11. Emergency fire exit, door should open from the floor to staircase only and not the other way round. The door should be in red reflector & arrow marks should commensurate with the gradient of staircase.
12. Do's & don'ts in times of emergencies should be available in a laminated hanging pad or otherwise in the telephone operator's desk as well as in the CE or emergency in charge of the officer's desk.
13. Alternate staircase should be kept free without any obstruction.
14. All staircases should be kept open during office hours and should be kept usable at any point of emergency.
15. Fire order / contingency plan should be prepared and displayed in each floor. It should also contain the rescue team members name, designation and contact number.
16. As per section 3.2 of BIS 12459, 1988 – code of practice for fire safety in cable regularization, 1m transparent fire retardant coatings shall be applied to all cables at termination points in electrical panels and all cables inside the distribution boxes.


for Director, 23.5.24
Fire and Rescue Services,
Tamil Nadu.

To:

M/s. Padanilam Welfare Trust,
Velayudhan Pillai Memorial Hospital Complex,
Kulasekharam,
Kanniyakumari District.



Copy to:

The Deputy Director, Fire and Rescue Services,
Tirunelveli Region, Tirunelveli.

KULASEKHARAM FIRE AND RESCUE SERVICE STATION

No:18/2026

Dated: 16.05.2026

NO OBJECTION CERTIFICATE

Subject: Fire and Rescue Service Department, Kulasekharam Fire and rescue service station – To issue No Objection Certificate - to Grant Affiliation for Schools - Regarding

Reference: 1. G.O.M.S.No.122, School Education Department Dated:14.09.2004.
2. G.O.M.S.No.123,School Education Department Dated:14.09.2004.
3. Director of Fire and Rescue Service Department Letter C.No.17483/C1/2004, Dated:29.09.2004.
4. Application Received Date:16.05.2026 C.K. Velayuthan Nair, THRAYAMBIKA VIDYA MANDIR SCHOOL, Cheruppaloor.

According to the Government orders and the application cited in the reference, The Station officer Transport Tr.A.Selvamurugesan inspected the **THRAYAMBIKA VIDYA MANDIR SCHOOL** established in the address at **D.No: 12-305/1, 12-305/2, 12-305/3 (Admin Block), 12-305/4, 12-305/5(Senior Secondary Block), 12-305/6(Kinder World)** Cheruppaloor, Kulasekharam Town Panchayat, Kulasekharam 'B' Village, Thiruvattar Taluk, Kanyakumari District on 16.05.2026 The Department of Fire & Rescue Service has No Objection granting recognition/ approval to the School in the said place.


Kulasekharam Fire and Rescue Service Station

With date and Seal



Signature:

Date:


STATION OFFICER
FIRE AND RESCUE STATION
KULASEKHARAM - 629 161

Designation: Station Officer,
Fire & Rescue Service Station,
Kulasekharam.

To: Dr. C.K. Velayuthan Nair, THRAYAMBIKA VIDYA MANDIR SCHOOL,
Cheruppaloor Post,

Copy to: The District Officer, Fire & Rescue Service Kanyakumari District.